

[Home](#) ■ [Solutions](#) ■ [Energy Efficiency](#) ■ [Wastewater Collection and Treatment](#) ■ [Effluent Filtration](#)

Energy-Efficient Effluent Filtration





Effluent filtration serves for increased removal of suspended solids (SS), BOD, COD, phosphorus (P) and nitrogen (N). About 20 % of German effluent is filtered.

The following filters are in common use:

- Multi-layer and multi-chamber sand filters with periodic water and air backwashing consume around 2.0 kWh/(PE•a) power;
- Continuous moving bed sand filter (e.g. our [CONTIFLOW® Sandfilter CFSF](#)) consume about 1.5 kWh/(PE•a);
- Microstrainers with a mesh size of 10 – 100 micron (e.g. our [RoDisc® Rotary Mesh Screen](#)) consume ca. 1.0 kWh/(PE•a);
- [Membrane Bio-Reactors](#) perform not only biological treatment, but also excellent filtration.

Where precipitation or flocculation is required, sand filters should be provided. Multi-layer sand filters are used at large wastewater plants, while continuous sand filters are more economic at small to medium-size plants.

Microstrainers are less effective than sand filters, but they are significantly less expensive and consume less power.

The following table provides a comparison:

	CONTIFLOW® Sandfilter CFSF		Microstrainer RoDisc® Rotary Mesh Screen	
	SS feed concentration	20 mg/l	60 mg/l	20 mg/l
SS effluent conc.	< 3 mg/l	< 10 mg/l	< 5 mg/l	< 15 mg/l
Power consumption at peak flow	≈ 10 Wh/m ³	≈ 12 Wh/m ³	≈ 4 Wh/m ³	≈ 6 Wh/m ³



Hydroflux Pty Ltd
Level 26, 44 Market St
Sydney NSW 2000
Australia

Phone +61 2 9089 8833
Fax +61 2 9089 8830
Email info@hydroflux.com.au
WWW www.huber-technology.net.au

Representative of the HUBER group:
www.huber.de
